



Certificate of Conformity

Certificate No: 2066AS12AVSV37688

Equipment: Grid-tied Photovoltaic inverter

Brand Name:  **FoxESS**

Test Model No: S700, S1000, S1500, S2000, S2500, S3000, S3300

Applicant: Maitian Energy Co., Ltd

Report No: AVSV-ESH-P20121037

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with DIN V VDE V 0126-1-1:2006+A1:2012 DIN V VDE V 0126-1-1:2013 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards:

DIN V VDE V 0126-1-1:2006+A1:2012

DIN V VDE V 0126-1-1:2013

Automatic disconnecting facility between the grid-connected generator and the electric power grid



This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.