



APPROVALS®

Certificate of Suitability

Addendum

Certificate No.: SAA200692

Date of Issue: 23 April 2020

Regulatory Definition: Non-Prescribed

Product Description: Grid-connected PV Inverter

Additional Models	Trade Name	Rating
E3600	FoxESS; FoxEss;	PV input: Max 600Vdc, MPPT Voltage range: 80-550Vdc, Max 12.5A/12.5A, Isc PV: 15A/15A AC output: 230Vac 50Hz 3600VA, Max 17.2A
F4600	FoxESS; FoxEss;	PV input: Max. 600Vdc, MPPT Voltage range: 80-550Vdc, Max 12.5A /12.5A, Isc PV: 15A/15A AC output: 230Vac 50Hz 4600VA, Max 22.0A
F5000	FoxESS; FoxEss;	PV input: Max. 600Vdc, MPPT Voltage range: 80-550Vdc, Max 12.5A /12.5A, Isc PV: 15A/15A AC output: 230Vac 50Hz 5000VA, Max 23.9A
F6000	FoxESS; FoxEss;	PV input: Max. 600Vdc, MPPT Voltage range: 80-550Vdc, Max 12.5A /12.5A, Isc PV: 15A/15A AC output: 230Vac 50Hz 6000VA, Max 26.1A

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 23-04-20 200692/2