



A P P R O V A L S ®

## Certificate of Suitability

\*Addendum\*

**Certificate No.:** SAA210720

**Date of Issue:** 19 April 2021

**Regulatory Definition:** Non-Prescribed

**Product Description:** Grid-connected PV Inverter

Additional Models	Trade Name	Rating/Marking
T17	FoxESS	PV input: Max 1100Vdc, MPPT voltage range: 160-850Vdc, Max 25.0/25.0A, Isc PV: 32.5/32.5A Output: 3/N/PE, 400Vac, 50/60Hz, Max 27.1A, Rated 17000VA, Max 18700VA Class I, IP65, -20°C to +60°C
T20	FoxESS	PV input: Max 1100Vdc, MPPT voltage range: 160-850Vdc, Max 25.0/25.0A, Isc PV: 32.5/32.5A Output: 3/N/PE, 400Vac, 50/60Hz, Max 31.9A, Rated 20000 VA, Max 22000VA Class I, IP65, -20°C to +60°C

*R. A. Hill*


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 19-04-21 210720/4a  
Rating/Markings corrected