

Certificate of Conformity

Registered No.:

COCPPV07103/22E-02

File reference
PVP07103/22E-01

Test report No.
TRPVP07103/22E/01

Date of issue
2022-11-21

On the basis of the tests undertaken, the samples of the below product(s) have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out:

Applicant: **FOXESS CO., LTD.**
Room A203, Building C, No 205, Binghai Six Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang Province.

Manufacturer: **FOXESS CO., LTD.**
Room A203, Building C, No 205, Binghai Six Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang Province.

Factory : **FOXESS CO., LTD. WUXI BRANCH**
No. 11, Lijing Road, Xinwu District, Wuxi City, Jiangsu Province, China.

Product: Storage Inverter

Type designation: H1-6.0-E, H1-5.0-E, H1-4.6-E, H1-3.7-E, H1-3.0-E
AIO-H1-6.0, AIO-H1-5.0, AIO-H1-4.6, AIO-H1-3.7, AIO-H1-3.0

Type of equipment: Interface device
 Interface protection
 Static conversion device
 Rotary generation device
Remark: The device is for plants of each power.

Certification fundamental(s): BOS-P-01 Rev. 00

Standard(s): CEI 0-21:2019-04 "Reference technical rules for the connection of active and passive users to the LV electrical Utilities"
See test report for detailed information.

Certification body: **TÜV NORD (HANGZHOU) CO., LTD.**
Room B409, Building 1, No 9 Jiuhuan Road, Shangcheng District, Hangzhou, Zhejiang Province, 310019, China



Renewable Energy

ESS-T-012 COC



中国认可
产品
PRODUCT
CNAS C183-P

Page 1 of 6

TÜV NORD (HANGZHOU) CO., LTD.
Member of TÜV NORD Group
Tel: +86-571-85386989
Fax: +86-571-85386986
www.tuv-nord.com/cn
P.R. China

Version 1.2

Accredited by CNAS according to ISO/IEC 17065:2012, certificate no. CNAS C183-P.

Testing laboratory:

Dongguan BALUN Testing Technology Co., Ltd.

Room 104/204/205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China.

Accredited by CNAS according to ISO/IEC 17025:2017, certificate no. CNAS L14701.

Conclusion:

After verifying following documents, it is concluded that the product is in compliance with the requirements of CEI 0-21:2019-04.

ISO 9001 certificate:

Certificate no. 200336, issued by DCI certification Ltd.

Test report of CEI 0-21:2019-04:

Report no. BL-DG2280174-B01 issued by Dongguan BALUN Testing Technology Co., Ltd., accredited by CNAS according to ISO/IEC 17025:2017, certificate no. CNAS L14701

Test report of EMC:

Report no. 4861920333200&4861921219500, issued by TÜV SÜD Certification and Testing (China) Co., Ltd., accredited by CNAS according to ISO/IEC 17025:2017, certificate no. CNAS L2282.

Report no. BL-DG2130790-402&BL-DG2130790-403, issued by Dongguan BALUN Testing Technology Co., Ltd., accredited by CNAS according to ISO/IEC 17025:2017, certificate no. CNAS L14701

Report no. C21-342-WT, issued by Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd., accredited by CNAS according to ISO/IEC 17025:2017, certificate no. CNAS L0130

This document is based on the evaluation of the samples of the above mentioned product(s). It does not imply an assessment of the mass-production of the product(s), and it does not permit the use of a TÜV NORD mark. The holder of this document may use it in connection with the related test report(s).



Renewable Energy

ESS-T-012 COC



中国认可
产品
PRODUCT
CNAS C183-P

Page 2 of 6

TÜV NORD (HANGZHOU) CO., LTD.
Member of TÜV NORD Group
Tel: +86-571-85386989
Fax: +86-571-85386986
www.tuv-nord.com/cn
P.R. China

Version 1.2

Description of product(s):

Model types.....:	H1-3.0-E/ AIO-H1-3.0	H1-3.7-E/ AIO-H1-3.7	H1-4.6-E/ AIO-H1-4.6	H1-5.0-E/ AIO-H1-5.0	H1-6.0-E/ AIO-H1-6.0
General information					
Firmware.....:	V1.09				
PV input:					
Vmax PV [V d.c.].....:	600				
Mpp voltage range [V d.c.]...:	80 - 550				
Isc PV [A d.c.].....:	15/15	15/15	15/15	15/15	15/15
Max. input current [A d.c.]...:	13.5/13.5	13.5/13.5	13.5/13.5	13.5/13.5	13.5/13.5
Overvoltage category (OVC).....:	II				
Battery input parameters:					
Battery Type.....:	Lithium-Ion				
Voltage range[V d.c.].....:	H1-3.0-E, H1-3.7-E, H1-4.6-E, H1-5.0-E, H1-6.0-E: 85-450 AIO-H1-3.0, AIO-H1-3.7, AIO-H1-4.6, AIO-H1-5.0, AIO-H1-6.0: 85-210				
Max. Charge Current [Ad.c.]:	40				
Max. Discharge Current [Ad.c.].....:	40				
AC output (Grid Side) parameters:					
Rated output voltage [V a.c.].....:	220/230/240				
Rated output frequency [Hz].....:	50/60				
Rated output power [W].....:	3000	3680	4600	5000	6000
Max. apparent power [VA]...:	3300	4048	5060	5500	6600
Max. output current [A a.c.]...:	14.4	17.6	22	23.9	28.7
Power factor cosφ [λ].....:	1 default (adjustable +/-0.8)				



Renewable Energy

ESS-T-012 COC


 中国认可
 产品
PRODUCT
CNAS C183-P

 TÜV NORD (HANGZHOU) CO., LTD.
 Member of TÜV NORD Group
 Tel: +86-571-85386989
 Fax: +86-571-85386986
 www.tuv-nord.com/cn
 P.R. China

AC output (Back-up) parameters:					
Rated output voltage [V a.c.].....:	220/230/240				
Rated output frequency [Hz].....:	50/60				
Rated output power [W].....:	5000	5000	6000	6000	6000
Max. apparent power [VA]....:	5000	5000	6000	6000	6000
Max. output current [A a.c.]..:	21.7	21.7	26.1	26.1	26.1
Power factor $\cos\phi$ [λ].....:	1 default (adjustable +/-0.8)				
Overvoltage category (OVC).....:	III				
The inverters listed above may be installed with the following batteries:					
Manufacturer	FOXESS Co., Ltd.(for H1 series)				
Accumulator Model / Battery Model	HS 5.2	HS 7.8	HS 10.4	HS 13	
Capacity of each battery module (kWh)	2.6				
Number(s) of battery modules recommended by the manufacturer (HV2600)	2	3	4	5	
Manufacturer	FOXESS Co., Ltd.(for H1 series)				
Accumulator Model / Battery Model	HS 15.6		HS 18.2		
Capacity of each battery module (kWh)	2.6				
Number(s) of battery modules recommended by the manufacturer (HV2600)	6		7		
Manufacturer	FOXESS Co., Ltd.(for AIO-H1 series)				
Accumulator Model / Battery Model	HVS 5.2	HVS 7.8	HVS 10.4		
Capacity of each battery module (kWh)	2.6				
Number(s) of battery modules recommended by the manufacturer (HV2600)	2	3	4		
Manufacturer	FOXESS Co., Ltd.(for H1 series)				
Accumulator Model / Battery Model	ECS2900-H2	ECS2900-H3	ECS2900-H4		
Capacity of each battery module (kWh)	2.88				
Number(s) of battery modules recommended by the manufacturer (CM2900&CS2900)	1+1	1+2	1+3		



Renewable Energy

ESS-T-012 COC


 中国认可
 产品
 PRODUCT
 CNAS C183-P

 TÜV NORD (HANGZHOU) CO., LTD.
 Member of TÜV NORD Group
 Tel: +86-571-85386989
 Fax: +86-571-85386986
 www.tuv-nord.com/cn
 P.R. China

Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	ECS2900-H5	ECS2900-H6	ECS2900-H7
Capacity of each battery module (kWh)	2.88		
Number(s) of battery modules recommended by the manufacturer (CM2900&CS2900)	1+4	1+5	1+6
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	ECS4100-H2	ECS4100-H3	ECS4100-H4
Capacity of each battery module (kWh)	4.03		
Number(s) of battery modules recommended by the manufacturer (CM4100&CS4100)	1+1	1+2	1+3
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	ECS4100-H5	ECS4100-H6	ECS4100-H7
Capacity of each battery module (kWh)	4.03		
Number(s) of battery modules recommended by the manufacturer (CM4100&CS4100)	1+4	1+5	1+6
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	ECS4300H-H2	ECS4300H-H3	ECS4300H-H4
Capacity of each battery module (kWh)	4.15		
Number(s) of battery modules recommended by the manufacturer (CM4300H&CS4300H)	1+1	1+2	1+3
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	ECS4300H-H5	ECS4300H-H6	ECS4300H-H7
Capacity of each battery module (kWh)	4.15		
Number(s) of battery modules recommended by the manufacturer (CM4300H&CS4300H)	1+4	1+5	1+6

Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	HS 5	HS 7.5	HS 10
Capacity of each battery module (kWh)	2.45		
Number(s) of battery modules recommended by the manufacturer (Mira-BMS&Mira-HV25)	1+2	1+3	1+4
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	HS 12.5	HS 15	HS 17.5
Capacity of each battery module (kWh)	2.45		
Number(s) of battery modules recommended by the manufacturer (Mira-BMS&Mira-HV25)	1+5	1+6	1+7
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	HS 20	--	--
Capacity of each battery module (kWh)	2.45		
Number(s) of battery modules recommended by the manufacturer (Mira-BMS&Mira-HV25)	1+8	--	--
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	ECS2800H-H2	ECS2800H-H3	ECS2800H-H4
Capacity of each battery module (kWh)	2.76		
Number(s) of battery modules recommended by the manufacturer (CM2800H&CS2800H)	1+1	1+2	1+3
Manufacturer	FOXESS Co., Ltd.(for H1 series)		
Accumulator Model / Battery Model	ECS2800H-H5	ECS2800H-H6	ECS2800H-H7
Capacity of each battery module (kWh)	2.76		
Number(s) of battery modules recommended by the manufacturer (CM2800H&CS2800H)	1+4	1+5	1+6
Note: The batteries are not integrated into the inverter and must be installed according to the local regulations.			