



CERTIFICATE OF PRODUCT CERTIFICATION

SOLAR PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC23024374802

Valid from: Jan.19,2023

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT FOXESS CO., LTD.
No.939, Jinhai Third Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang, China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER FOXESS CO., LTD.
No.939, Jinhai Third Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang, China

NAME AND LOCATION OF THE FACTORY FOXESS CO., LTD.
No.939, Jinhai Third Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang, China

PRODUCT NAME, MODEL AND SPECIFICATION R SERIES 3-PHASE GRID-TIED INVERTERS
R75、R100、R110 (See Appendix)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 37408-2019

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461239-2018.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE OF PRODUCT CERTIFICATION

SOLAR PRODUCT CERTIFICATE

APPENDIX

Page 1 of 1

CERTIFICATE NO.: CQC23024374802

PAPER:

R110

直流输入: MPPT 电压范围 200V-1000Vdc, 最大直流输入电压 1100Vdc, 最大输入电流 26A*10; 交流输出: 3/N/PE~, 380V/400V, 50Hz, Max. 175. 3A, 额定交流输出功率 110kW.

R100

直流输入: MPPT 电压范围 200V-1000Vdc, 最大直流输入电压 1100Vdc, 最大输入电流 26A*9; 交流输出: 3/N/PE~, 380V/400V, 50Hz, Max. 158. 8A, 额定交流输出功率 100kW.

R75

直流输入: MPPT 电压范围 200V-1000Vdc, 最大直流输入电压 1100Vdc, 最大输入电流 26A*9; 交流输出: 3/N/PE~, 380V/400V, 50Hz, Max. 119. 6A, 额定交流输出功率 75kW.

NOTE: This appendix is valid when used with the certificate.



CHINA QUALITY CERTIFICATION CENTRE