



Fair
Trading

File Ref: CS11092/2
Contact: Admin Clerk
Telephone: 02 9895 0722

JIANYONG LI
FOXESS Co., Ltd.
C/- TUV SUD CERTIFICATION AND TESTING
(CHINA) CO., LTD. SHANGHAI BRANCH
3-13, No.151, Heng Tong Road
Shanghai, China 200070

Dear Sir/Madam

VARIATION TO CERTIFICATE OF SUITABILITY: CS11092N

Inverter

Please find enclosed an addendum to the certificate as sought in your application.

Yours faithfully,

28 October 2022

For Secretary, Department of Customer Service



Fair
Trading

Ref: CS11092/2

ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11092N Particulars of Modification(s)

The Rated Output Apparent Power for Models AIO-AC1-5.0-HVS7.8, and AIO-AC1-5.0-HVS10.4 has changed from 5500VA to 5000VA.

Certificate now complies with AS 62040.1:2019 and IEC 62619:2017.

General Modification:

For compliance with performance requirements refer to change from 'CQC Test Report No CQCTT-WT-2022-A0007a dated 18/05/2022.' To 'CQC Test Report No CQCTT-WT-2022-A0007a-d dated 18/05/2022, CQCTT-WT-2022-A0089a-e dated 18/08/2022 and TUV SUD test report No 5061920005102-01 dated 08/06/2021.'

This certificate will expire on 07/06/2027

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

28 October 2022

For Secretary, Department of Customer Service