



Fair  
Trading

Ref: CS11094/1

## ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11094N Particulars of Modification(s)

Model No. AIO-H1-5.0-HVS5.2 being similar to approved Model No. AIO-H1-6.0-HVS10.4 except for:

PV Input: Max. Input Power: 6500W

AC Input: Rated Input Current: 45.4Aa.c., Rated Apparent Power: 10000VA

AC Output: Rated Power: 5000W, Rated Apparent Power: 5500VA, Rated Output Current: 23.9Aa.c., Battery Capacity: 5.2kWh

Model No. AIO-H1-5.0-HVS7.8 being similar to approved Model No. AIO-H1-6.0-HVS10.4 except for:

PV Input: Max. Input Power: 6500W

AC Input: Rated Input Current: 45.4Aa.c., Rated Apparent Power: 10000VA

AC Output: Rated Power: 5000W, Rated Apparent Power: 5500VA, Rated Output Current: 23.9Aa.c., Battery Capacity: 7.8kWh

Model No. AIO-H1-5.0-HVS10.4 being similar to approved Model No. AIO-H1-6.0-HVS10.4 except for:

PV Input: Max. Input Power: 6500W

AC Input: Rated Input Current: 45.4Aa.c., Rated Apparent Power: 10000VA

AC Output: Rated Power: 5000W, Rated Apparent Power: 5500VA, Rated Output Current: 23.9Aa.c., Battery Capacity: 10.4kWh

Model No. AIO-H1-6.0-HVS5.2 being similar to approved Model No. AIO-H1-6.0-HVS10.4 except for Battery Capacity: 5.2kWh

Model No. AIO-H1-6.0-HVS7.8 being similar to approved Model No. AIO-H1-6.0-HVS10.4 except for Battery Capacity: 7.8kWh

This certificate will expire on 07/06/2027

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:  
7 June 2022

For Secretary, Department of Customer Service

9 June 2022